



IEEE POWER ENGINEERING SOCIETY
Power System Analysis, Computing and Economics Committee

Chair

MARTIN L. BAUGHMAN
Professor Emeritus
The University of Texas at Austin
5703 Painted Valley Drive
Austin, TX 78759
Vox: 512-345-8255
Fax: 512-345-9880
baughman@mail.utexas.edu

Vice Chair

CHEN-CHING LIU
Dept. of Electrical Eng.
University of Washington
Box 352500
Seattle, WA 98195
Vox: 206-543-2198
Fax: 206-543-3842
liu@ee.washington.edu

Secretary

ROGER C. DUGAN
Sr. Consultant
Electrotek Concepts, Inc.
408 N Cedar Bluff Rd
Knoxville, TN 37923
Vox: 865-470-9222
Fax: 865-470-9223
r.dugan@ieee.org

Subcommittee Chairs

Computer & Analytical Methods

EDWIN LIU, Chair
Nexant, Inc.
101, 2nd street, 11F
San Francisco CA 94105
Vox: 415-369-1088
Fax: 415-369-0894
exliu@nexant.com

Distribution Systems Analysis

SANDOVAL CARNEIRO, JR, Chair
Dept. of Electrical Engineering
Federal Univ. of Rio de Janeiro
Rio de Janeiro, RJ, Brazil
Vox: 55-21-25628025
Fax: 55-21-25628628
sandoval@coep.ufrj.br

Intelligent System Applications

DAGMAR NIEBUR, Chair
Department of ECE
Drexel University
3141 Chestnut Street
Philadelphia, PA 19104
Vox: (215) 895 6749
Fax: (215) 895 1695
niebur@cbis.ece.drexel.edu

Reliability, Risk & Probability Applications

JAMES D. MCCALLEY, Chair
Iowa State University
Room 2210 Coover Hall
Ames, Iowa 50011
Vox: 515-294-4844
Fax: 515-294-4263
jdm@jastate.edu

Systems Economics
ROSS BALDICK, Chair
ECE Dept., ENS 502
The University of Texas at Austin
Austin, TX 78712
Vox: 512-471-5879
Fax: 512-471-5532
baldick@ece.utexas.edu

Past Chair
JOANN V. STARON
Nexant Inc/ PCA
1921 S. Alma School Road
Suite 207
Mesa, AZ 85210
Vox: 480-345-7600
Fax: 480-345-7601
joann.staron@pca-corp.com

Distribution System Analysis Subcommittee

**IEEE Wye-Delta Center
Tapped Transformer Test
Feeder**

Data and Solutions

Transformer Connections

- **Ungrounded Wye-Delta**
- **Grounded Wye-Delta**
- **“Leading” Open Wye- Delta**
- **“Lagging” Open Wye-Delta**



IEEE Four-Wire Delta Test Feeder

The system to be used in testing four wire delta transformer models is shown in Figure 1. This system is used to model the following transformer connections:

- Ungrounded wye-delta
- Grounded wye-delta
- Leading open wye-open delta
- Lagging open wye-open delta




Figure 1 – Four Wire Delta Test Feeder

Three-Phase Circuit:

The three-phase circuit to be analyzed for the ungrounded wye-delta connection is shown in Figure 2. The grounded wye-delta connection will have a connection from the primary transformer neutral to the distribution line grounded neutral. The “leading” open wye – open delta connection will ground the transformer primary neutral and remove the transformer on phase C. The “lagging” open wye – open delta connection will remove the transformer on phase B from the original connection.




Figure 2 – Three-Phase Circuit



Equivalent Source

Balanced line-to-ground voltages of 7200 volts with abc rotation.

Primary Line:

The primary line will be constructed using the pole configuration shown in Figure 3.




Figure 3 – Pole Configuration

Phase Conductors: 556,500 26/7 ACSR

GMR = 0.0313 ft., Resistance = 0.1859 Ω/mile, Diameter = 0.927 inch

Neutral Conductor: 4/0 6/1 ACSR

GMR = 0.00814 ft., Resistance = 0.492 Ω/mile, Diameter = 0.563 inch

Length of line = 5 miles

Primitive four -wire impedance matrix:

$$z_{\text{p}} = \begin{pmatrix} 0.2812 + 1.383j & 0.0953 + 0.7266j & 0.0953 + 0.8515j & 0.0953 + 0.7524j \\ 0.0953 + 0.7266j & 0.2812 + 1.383j & 0.0953 + 0.7802j & 0.0953 + 0.7674j \\ 0.0953 + 0.8515j & 0.0953 + 0.7802j & 0.2812 + 1.383j & 0.0953 + 0.7865j \\ 0.0953 + 0.7524j & 0.0953 + 0.7674j & 0.0953 + 0.7865j & 0.6873 + 1.5465j \end{pmatrix} \Omega/\text{mile}$$

Kron reduced equivalent three-wire impedance matrix:

$$z_{\text{abc}} = \begin{pmatrix} 0.3375 + 1.0478j & 0.1535 + 0.3849j & 0.1559 + 0.5017j \\ 0.1535 + 0.3849j & 0.3414 + 1.0348j & 0.158 + 0.4236j \\ 0.1559 + 0.5017j & 0.158 + 0.4236j & 0.3465 + 1.0179j \end{pmatrix} \Omega/\text{mile}$$

Secondary Line:

The secondary line is quadruplex cable as shown in Figure 4.




Figure 4 – Quadruplex Cable

Phase Conductor: 4/0 AA

GMR = 0.0158 ft., Resistance = 0.484 Ω/mile, Diameter = 0.522 inch

Neutral Conductor: 4/0 6/1 ACSR

GMR = 0.00814 ft., Resistance = 0.592 Ω/mile, Diameter = 0.563 inch

Insulation Thickness = 0.2 inch

Length of Secondary = 100 ft.

Four Wire Impedance Matrix:

$$Z_q = \begin{pmatrix} 0.5793 + 1.466j & 0.0953 + 1.2741j & 0.0953 + 1.2741j & 0.0953 + 1.3004j \\ 0.0953 + 1.2741j & 0.5793 + 1.466j & 0.0953 + 1.2741j & 0.0953 + 1.2251j \\ 0.0953 + 1.2741j & 0.0953 + 1.2741j & 0.5793 + 1.466j & 0.0953 + 1.3004j \\ 0.0953 + 1.3004j & 0.0953 + 1.2251j & 0.0953 + 1.3004j & 0.6873 + 1.5465j \end{pmatrix} \Omega/\text{mile}$$

Kron Reduced Equivalent Three-Wire Impedance Matrix:

$$Z_{sec} = \begin{pmatrix} 0.8491 + 0.4984j & 0.3455 + 0.361j & 0.3651 + 0.3064j \\ 0.3455 + 0.361j & 0.8112 + 0.6044j & 0.3455 + 0.361j \\ 0.3651 + 0.3064j & 0.3455 + 0.361j & 0.8491 + 0.4984j \end{pmatrix} \Omega/\text{mile}$$

Transformer Data

Power Transformers Phase A: 10 kVA, 7200-120/240, per-unit $Z_P = 0.016 + j0.014$

Lighting Transformers Phase B &C: 25 kVA, 7200-120/240, per-unit $Z_L = 0.012 + j0.017$

For an interlaced lighting transformer:

$$Z_A = 0.5 \cdot R_L + j0.8 \cdot X_L \quad \text{per-unit}$$

$$Z_a = Z_b = R_L + j0.4 \cdot X_L$$

Impedances in Ohms per the circuit diagram of Figure 5:

$$Z_A = 12.4416 + j28.201$$

$$Z_a = Z_b = 0.006912 + j0.003917 \quad \text{Ohms}$$

$$Z_B = Z_C = 82.944 + j72.576$$

The connection diagram for the three transformers connected in ungrounded wye-delta is shown in Figure 5.




Figure 5 – Transformer Connection Diagram

Load Data

Three-Phase Induction Motor:

25 Hp, 240 volt

$$Z_{stator} = 0.0774 + j0.1843$$

$$Z_{rotor} = 0.0908 + j0.1843 \quad \text{Ohms}$$

$$Z_m = 0 + j4.8384$$

$$\text{Slip} = 0.035$$

Three-phase motor admittance and impedance matrices for slip = 0.035

$$YM_{abc} = \begin{pmatrix} 0.7452 - 0.4074j & -0.0999 - 0.0923j & 0.3547 + 0.4997j \\ 0.3547 + 0.4997j & 0.7452 - 0.4074j & -0.0999 - 0.0923j \\ -0.0999 - 0.0923j & 0.3547 + 0.4997j & 0.7452 - 0.4074j \end{pmatrix} \text{ S}$$

$$ZM_{abc} = \begin{pmatrix} 1.0991 + 1.3888j & -0.9987 - 0.3165j & 0.8996 - 1.0723j \\ 0.8996 - 1.0723j & 1.0991 + 1.3888j & -0.9987 - 0.3165j \\ -0.9987 - 0.3165j & 0.8996 - 1.0723j & 1.0991 + 1.3888j \end{pmatrix} \Omega$$

Lighting Loads:


$SL_{an} = 3 \text{ kVA}$ at 0.95 lagging power factor

$SL_{bn} = 5 \text{ kVA}$ at 0.85 lagging power factor

$SL_{ab} = 10 \text{ kVA}$ at 0.90 lagging power factor



Ungrounded Wye-Delta Solution



Source LG Voltages

$$\begin{aligned} ES_{AG} &= 7,200/0 \\ ES_{BG} &= 7,200/-120 \\ ES_{CG} &= 7,200/120 \end{aligned} \quad V$$

Primary Line Voltage Drops

$$\begin{aligned} v_A &= 8.6057/47.57 \\ v_B &= 6.1279/-104.47 \\ v_C &= 4.5188/174.26 \\ v_N &= 0 \end{aligned} \quad V$$

Transformer Primary LN Voltages

$$\begin{aligned} V_{AN} &= 7,130.94/-0.08 \\ V_{BN} &= 7,228.90/-120.43 \\ V_{CN} &= 7,226.22/120.42 \end{aligned} \quad V$$

Source LL Voltages

$$\begin{aligned} ES_{AB} &= 12,470.77/30 \\ ES_{BC} &= 12,470.77/-90 \\ ES_{CA} &= 12,470.77/150 \end{aligned} \quad V$$

End of Line LG Voltages

$$\begin{aligned} V_{AG} &= 7,194.20/-0.05 \\ V_{BG} &= 7,194.10/-120.01 \\ V_{CG} &= 7,197.36/119.97 \end{aligned}$$

Transformer Primary LL Voltages

$$\begin{aligned} V_{AB} &= 12,458.27/29.97 \\ V_{BC} &= 12,464.38/-90.01 \\ V_{CA} &= 12,464.80/149.95 \end{aligned} \quad V$$



Neutral to Ground Voltage at Transformer Primary

$$V_{NG} = 63.3576/\underline{-3.10} \quad \text{V}$$

Primary Windings Ideal Voltages

$$\begin{aligned} VT_{AN} &= 7,063.30/\underline{-0.49} \\ VT_{BN} &= 7,040.38/\underline{-120.05} \\ VT_{CN} &= 7,079.80/\underline{119.61} \end{aligned} \quad \text{V}$$

Primary Line, Neutral and Ground Currents

$$\begin{aligned} I_A &= 2.7513/\underline{-29.37} \\ I_B &= 1.7654/\underline{-175.76} \\ I_C &= 1.6112/\underline{113.29} \quad \text{A} \\ I_N &= 0.0403/\underline{-21.28} \\ I_G &= 0.0403/\underline{158.72} \end{aligned}$$

Transformer Secondary Windings Ideal Voltages Transformer Secondary Terminal Voltages

$$\begin{aligned} V_{t_{an}} &= 117.72/\underline{-0.49} \\ V_{t_{nb}} &= 117.72/\underline{-0.49} \\ V_{t_{bc}} &= 234.68/\underline{-120.05} \\ V_{t_{ca}} &= 235.99/\underline{119.61} \end{aligned} \quad \text{A}$$

$$\begin{aligned} V_{an} &= 117.14/\underline{-0.51} \\ V_{nb} &= 116.99/\underline{-0.48} \\ V_{ab} &= 234.13/\underline{-0.50} \quad \text{V} \\ V_{bc} &= 234.68/\underline{-120.05} \\ V_{ca} &= 235.99/\underline{119.61} \end{aligned}$$

Transformer Secondary Winding Currents

$$\begin{aligned} I_{na} &= 73.67/\underline{-26.59} \\ I_{bn} &= 91.56/\underline{-31.61} \\ I_{cb} &= 52.96/\underline{-175.76} \\ I_{ac} &= 48.34/\underline{113.29} \end{aligned} \quad \text{A}$$

Secondary Line, Neutral and Ground

$$\begin{aligned} I_a &= 114.93/\underline{-41.32} \\ I_b &= 138.02/\underline{161.37} \\ I_c &= 58.91/\underline{55.09} \quad \text{A} \\ I_n &= 10.59/\underline{-51.66} \\ I_g &= 8.69/\underline{-50.55} \end{aligned}$$

Secondary Line Voltage Drops

$$\begin{aligned} v_a &= 1.0321/\underline{-30.14} \\ v_b &= 1.5515/\underline{-172.65} \\ v_c &= 0.4488/\underline{94.39} \\ v_n &= 0 \end{aligned} \quad \text{V}$$

Single-Phase Load Voltages

$$\begin{aligned} VL_{an} &= 116.24/\underline{-0.26} \\ VL_{nb} &= 115.46/\underline{-0.59} \quad \text{V} \\ VL_{ab} &= 231.70/\underline{-0.42} \end{aligned}$$



Single-Phase Load Currents

$$\begin{aligned} IL_{an} &= 25.81/-18.45 \\ IL_{nb} &= 43.31/-32.38 \quad \text{A} \\ IL_{ab} &= 43.16/-26.26 \end{aligned}$$

Single-Phase Complex Powers

$$\begin{aligned} S_{an} &= \frac{VL_{an} \cdot (IL_{an})^*}{1000} = 3.0 @ 0.95 PF \\ S_{nb} &= \frac{VL_{nb} \cdot (IL_{nb})^*}{1000} = 5.0 @ 0.85 PF \quad \text{kVA} \\ S_{ab} &= \frac{VL_{ab} \cdot (IL_{ab})^*}{1000} = 10.0 @ 0.90 PF \end{aligned}$$

Motor LL Voltages

$$\begin{aligned} VL_{ab} &= 231.70/-0.42 \\ VL_{bc} &= 233.37/-119.81 \quad \text{V} \\ VL_{ca} &= 234.70/119.53 \end{aligned}$$

Motor Line Currents

$$\begin{aligned} IM_a &= 54.65/-66.49 \\ IM_b &= 55.54/178.15 \quad \text{A} \\ IM_c &= 58.91/55.09 \end{aligned}$$

Transformer Operating kVAs

$$\begin{aligned} S_A &= \frac{V_{AN} \cdot (I_A)^*}{1000} = 17.11 + j9.60 = 19.62 \text{ kVA} @ 0.87 \text{ PF} \\ S_B &= \frac{V_{BN} \cdot (I_B)^*}{1000} = 7.26 + j10.50 = 12.76 \text{ kVA} @ 0.57 \text{ PF} \\ S_C &= \frac{V_{CN} \cdot (I_C)^*}{1000} = 11.55 + j1.45 = 11.64 \text{ kVA} @ 0.99 \text{ PF} \end{aligned}$$

INDUCTION MOTOR ANALYSIS

Stator Input Complex Power

$$\begin{aligned} S_{stator} &= 18.83 + j12.79 \text{ kVA} \\ S_{stator} &= 22.77 \text{ kVA} @ 0.8271 \text{ PF} \end{aligned}$$

Rotor Currents

$$\begin{aligned} I_{rotor_a} &= 45.89/-38.29 \\ I_{rotor_b} &= 48.63/-154.15 \quad \text{A} \\ I_{rotor_c} &= 50.24/81.13 \end{aligned}$$

Losses

$$\begin{aligned} Stator_{loss} &= 738.65 \\ Rotor_{loss} &= 634.91 \quad \text{W} \\ Total_{loss} &= 1,373.56 \end{aligned}$$

Converted Shaft Power


$$\begin{aligned} P_{converted} &= 17.46 \text{ kW} \\ P_{converted} &= 23.40 \text{ Hp} \end{aligned}$$

NEMA Unbalances

$$\begin{aligned} V_{unbalance} &= 0.6671 \% \\ I_{unbalance} &= 3.0525 \end{aligned}$$



Grounded Wye-Delta Solution



Source LG Voltages

$$\begin{aligned} ES_{AG} &= 7,200 \angle 0^\circ \\ ES_{BG} &= 7,200 \angle -120^\circ \\ ES_{CG} &= 7,200 \angle 120^\circ \end{aligned}$$

Primary Line Voltage Drops

$$\begin{aligned} v_A &= 15.1049 \angle 38.92^\circ \\ v_B &= 5.1143 \angle -35.34^\circ \\ v_C &= 3.8637 \angle 68.05^\circ \\ v_N &= 0 \end{aligned}$$

Transformer Primary LN Voltages

$$\begin{aligned} V_{AN} &= 7,188.25 \angle -0.08^\circ \\ V_{BN} &= 7,199.53 \angle -120.04^\circ \\ V_{CN} &= 7,197.62 \angle 120.02^\circ \end{aligned}$$

Source LL Voltages

$$\begin{aligned} ES_{AB} &= 12,470.77 \angle 30^\circ \\ ES_{BC} &= 12,470.77 \angle -90^\circ \\ ES_{CA} &= 12,470.77 \angle 150^\circ \end{aligned}$$

End of Line LG Voltages

$$\begin{aligned} V_{AG} &= 7,188.25 \angle -0.08^\circ \\ V_{BG} &= 7,199.53 \angle -120.04^\circ \\ V_{CG} &= 7,197.62 \angle 120.02^\circ \end{aligned}$$

Transformer Primary LL Voltages

$$\begin{aligned} V_{AB} &= 12,457.98 \angle 29.97^\circ \\ V_{BC} &= 12,464.22 \angle -90.01^\circ \\ V_{CA} &= 12,464.80 \angle 149.95^\circ \end{aligned}$$



Neutral to Ground Voltage at Transformer Primary

$$V_{NG} = 0 \quad \text{V}$$

Primary Windings Ideal Voltages

$$\begin{aligned} VT_{AN} &= 7,101.69/-0.55 \\ VT_{BN} &= 7,046.53/-120.16 \\ VT_{CN} &= 7,089.46/119.70 \end{aligned} \quad \text{V}$$

Primary Line, Neutral and Ground Currents

$$\begin{aligned} I_A &= 3.3974/-32.26 \\ I_B &= 1.3949/-155.69 \\ I_C &= 1.0480/99.22 \quad \text{A} \\ I_N &= 0.8621/153.32 \\ I_G &= 1.1719/124.49 \end{aligned}$$

Transformer Secondary Windings Ideal Voltages Transformer Secondary Terminal Voltages

$$\begin{aligned} V_{t_{an}} &= 118.36/-0.55 \\ V_{t_{nb}} &= 118.36/-0.55 \\ V_{t_{bc}} &= 234.88/-120.16 \\ V_{t_{ca}} &= 236.32/119.70 \end{aligned} \quad \text{A}$$

$$\begin{aligned} V_{an} &= 117.62/-0.55 \\ V_{nb} &= 117.48/-0.52 \\ V_{ab} &= 235.10/-0.53 \quad \text{V} \\ V_{bc} &= 234.88/-120.16 \\ V_{ca} &= 236.32/119.70 \end{aligned}$$

Transformer Secondary Winding Currents

$$\begin{aligned} I_{na} &= 92.89/-30.34 \\ I_{bn} &= 111.05/-33.87 \\ I_{cb} &= 41.85/-155.69 \quad \text{A} \\ I_{ac} &= 31.44/99.22 \end{aligned}$$

Secondary Line, Neutral and Ground

$$\begin{aligned} I_a &= 115.49/-42.45 \\ I_b &= 137.78/161.09 \\ I_c &= 58.52/55.56 \quad \text{A} \\ I_n &= 10.51/-51.69 \\ I_g &= 8.68/-50.60 \end{aligned}$$

Secondary Line Voltage Drops

$$\begin{aligned} v_a &= 1.0378/-30.23 \\ v_b &= 1.5485/-172.90 \\ v_c &= 0.4468/95.11 \quad \text{V} \\ v_n &= 0 \end{aligned}$$

Single-Phase Load Voltages

$$\begin{aligned} VL_{an} &= 116.72/-0.29 \\ VL_{nb} &= 115.95/-0.62 \quad \text{V} \\ VL_{ab} &= 232.69/-0.46 \end{aligned}$$



Single-Phase Load Currents

$$IL_{an} = 25.70/-18.49$$

$$IL_{nb} = 43.12/-32.41 \quad A$$

$$IL_{ab} = 42.98/-26.30$$

Single-Phase Complex Powers

$$S_{an} = \frac{VL_{an} \cdot (IL_{an})^*}{1000} = 3.0 @ 0.95 PF$$

$$S_{nb} = \frac{VL_{nb} \cdot (IL_{nb})^*}{1000} = 5.0 @ 0.85 PF \quad kVA$$

$$S_{ab} = \frac{VL_{ab} \cdot (IL_{ab})^*}{1000} = 10.0 @ 0.90 PF$$

Motor LL Voltages

$$VL_{ab} = 232.69/-0.46$$

$$VL_{bc} = 233.58/-119.92 \quad V$$

$$VL_{ca} = 235.01/119.62$$

Motor Line Currents

$$IM_a = 54.45/-66.28$$

$$IM_b = 55.46/177.41 \quad A$$

$$IM_c = 58.52/55.56$$

Transformer Operating kVAs

$$S_A = \frac{V_{AN} \cdot (I_A)^*}{1000} = 20.67 + j13.00 = 24.42 \text{ kVA} @ 0.85 \text{ PF}$$

$$S_B = \frac{V_{BN} \cdot (I_B)^*}{1000} = 8.16 + j5.85 = 10.04 \text{ kVA} @ 0.81 \text{ PF}$$

$$S_C = \frac{V_{CN} \cdot (I_C)^*}{1000} = 7.05 + j2.68 = 7.54 \text{ kVA} @ 0.93 \text{ PF}$$

INDUCTION MOTOR ANALYSIS

Stotor Input Complex Power

$$S_{stator} = 18.91 + j12.85 \text{ kVA}$$

$$S_{stator} = 22.86 \text{ kVA} @ 0.8272 \text{ PF}$$

Rotor Currents

$$I_{rotor_a} = 46.67/-38.46$$

$$I_{rotor_b} = 48.26/-154.77 \quad A$$

$$I_{rotor_c} = 50.10/81.84$$

Losses

$$Stator_{loss} = 741.21$$

$$Rotor_{loss} = 636.97 \quad W$$

$$Total_{loss} = 1,378.18$$

Converted Shaft Power

$$P_{converted} = 17.53 \text{ kW}$$

$$P_{converted} = 23.50 \text{ Hp} \quad kW$$


NEMA Unbalances

$$V_{unbalance} = 0.5375 \quad \%$$

$$I_{unbalance} = 1.8197$$



Leading Open Wye-Delta Solution



Source LG Voltages

$$\begin{aligned} ES_{AG} &= 7,200/0 \\ ES_{BG} &= 7,200/-120 \\ ES_{CG} &= 7,200/120 \end{aligned} \quad \text{V}$$

Primary Line Voltage Drops

$$\begin{aligned} v_A &= 23.3548/21.30 \\ v_B &= 14.10/-18.11 \\ v_C &= 11.81/10.64 \\ v_N &= 0 \end{aligned} \quad \text{V}$$

Transformer Primary LN Voltages

$$\begin{aligned} V_{AN} &= 7,178.25/-0.07 \\ V_{BN} &= 7,202.92/-120.11 \\ V_{CN} &= 7,203.93 \end{aligned} \quad \text{V}$$

Source LL Voltages

$$\begin{aligned} ES_{AB} &= 12,470.77/30 \\ ES_{BC} &= 12,470.77/-90 \\ ES_{CA} &= 12,470.77/150 \end{aligned} \quad \text{V}$$

End of Line LG Voltages

$$\begin{aligned} V_{AG} &= 7,178.25/-0.07 \\ V_{BG} &= 7,202.92/-120.11 \\ V_{CG} &= 7,203.93/120.09 \end{aligned} \quad \text{V}$$

Transformer Primary LL Voltages

$$\begin{aligned} V_{AB} &= 12,457.10/29.97 \\ V_{BC} &= 12,464.20/-90.01 \\ V_{CA} &= 12,465.13/149.95 \end{aligned} \quad \text{V}$$



Neutral to Ground Voltage at Transformer Primary

$$V_{NG} = 0 \quad \text{V}$$

Primary Windings Ideal Voltages

$$\begin{aligned} VT_{AN} &= 7,061.39/-0.51 \\ VT_{BN} &= 7,035.15/-121.03 \end{aligned} \quad \text{V}$$

Primary Line, Neutral and Ground Currents

$$\begin{aligned} I_A &= 4.1845/-41.44 \\ I_B &= 1.845/-127.42 \\ I_C &= 0 \end{aligned} \quad \text{A}$$

$$\begin{aligned} I_N &= 2.1109/131.85 \\ I_G &= 2.7298/102.88 \end{aligned}$$

Transformer Secondary Windings Ideal Voltages Transformer Secondary Terminal Voltages

$$\begin{aligned} V_{t_{an}} &= 117.69/-0.51 \\ V_{t_{nb}} &= 117.69/-0.51 \\ V_{t_{bc}} &= 234.51/-121.03 \end{aligned} \quad \text{A}$$

$$\begin{aligned} V_{an} &= 116.78/-0.42 \\ V_{nb} &= 116.64/-0.40 \\ V_{ab} &= 233.42/-0.41 \end{aligned} \quad \text{V}$$

$$\begin{aligned} V_{bc} &= 234.51/-121.03 \\ V_{ca} &= 231.76/119.05 \end{aligned}$$

Transformer Secondary Winding Currents

$$\begin{aligned} I_{na} &= 116.00/-40.64 \\ I_{bn} &= 135.08/-42.12 \\ I_{cb} &= 55.30/-127.42 \end{aligned} \quad \text{A}$$

Secondary Line, Neutral and Ground

$$\begin{aligned} I_a &= 116.01/-40.64 \\ I_b &= 141.71/160.77 \\ I_c &= 55.30/52.58 \end{aligned} \quad \text{A}$$

$$\begin{aligned} I_n &= 10.49/-51.96 \\ I_g &= 8.87/-49.96 \end{aligned}$$

Secondary Line Voltage Drops

$$\begin{aligned} v_a &= 1.0372/-28.49 \\ v_b &= 1.5893/-173.14 \\ v_c &= 0.4032/93.07 \end{aligned} \quad \text{V}$$

$$v_n = 0$$

Single-Phase Load Voltages

$$\begin{aligned} VL_{an} &= 115.87/-0.18 \\ VL_{nb} &= 115.06/-0.50 \end{aligned} \quad \text{V}$$

$$VL_{ab} = 230.93/-0.34$$



Single-Phase Load Currents

$$IL_{an} = 25.89/-18.38$$

$$IL_{nb} = 43.45/-32.29 \quad A$$

$$IL_{ab} = 43.30/-26.18$$

Single-Phase Complex Powers

$$S_{an} = \frac{VL_{an} \cdot (IL_{an})^*}{1000} = 3.0 @ 0.95 PF$$

$$S_{nb} = \frac{VL_{nb} \cdot (IL_{nb})^*}{1000} = 5.0 @ 0.85 PF \quad kVA$$

$$S_{ab} = \frac{VL_{ab} \cdot (IL_{ab})^*}{1000} = 10.0 @ 0.90 PF$$

Motor LL Voltages

$$VL_{ab} = 230.93/-0.34$$

$$VL_{bc} = 233.20/-120.78 \quad V$$

$$VL_{ca} = 230.83/118.95$$

Motor Line Currents

$$IM_a = 54.19/-63.01$$

$$IM_b = 58.36/175.71 \quad A$$

$$IM_c = 55.30/52.58$$

Transformer Operating kVAs

$$S_A = \frac{V_{AN} \cdot (I_A)^*}{1000} = 22.54 + j19.85 = 30.04 \text{ kVA} @ 0.75 \text{ PF}$$

$$S_B = \frac{V_{BN} \cdot (I_B)^*}{1000} = 13.17 + j1.69 = 13.28 \text{ kVA} @ 0.99 \text{ PF}$$

INDUCTION MOTOR ANALYSIS

Stotor Input Complex Power

$$S_{stator} = 18.56 + j12.61 \text{ kVA}$$

$$S_{stator} = 22.43 \text{ kVA} @ 0.8271 \text{ PF}$$

Rotor Currents

$$I_{rotor_a} = 47.19/-34.79$$

$$I_{rotor_b} = 50.24/-158.18 \quad A$$

$$I_{rotor_c} = 46.27/80.19$$

Losses

$$Stator_{loss} = 727.81$$

$$Rotor_{loss} = 625.57 \quad W$$

$$Total_{loss} = 1,353.38$$

Converted Shaft Power

$$P_{converted} = 17.20 \text{ kW}$$

$$P_{converted} = 23.06 \text{ Hp} \quad kW$$


NEMA Unbalances

$$V_{unbalance} = 0.7103 \%$$

$$I_{unbalance} = 4.3100$$



Lagging Open Wye-Delta Solution



Source LG Voltages

$$\begin{aligned} ES_{AG} &= 7,200/0 \\ ES_{BG} &= 7,200/-120 \\ ES_{CG} &= 7,200/120 \end{aligned} \quad \text{V}$$

Source LL Voltages

$$\begin{aligned} ES_{AB} &= 12,470.77/30 \\ ES_{BC} &= 12,470.77/-90 \\ ES_{CA} &= 12,470.77/150 \end{aligned} \quad \text{V}$$

Primary Line Voltage Drops

$$\begin{aligned} v_A &= 24.51/64.26 \\ v_B &= 10.26/72.96 \\ v_C &= 16.36/90.38 \\ v_N &= 0 \end{aligned} \quad \text{V}$$

End of Line LG Voltages

$$\begin{aligned} V_{AG} &= 7,189.39/-0.18 \\ V_{BG} &= 7,210.00/-119.98 \\ V_{CG} &= 7,185.78/120.06 \end{aligned} \quad \text{V}$$

Transformer Primary LN Voltages

$$\begin{aligned} V_{AN} &= 7,189.39/-0.18 \\ V_{CN} &= 7,185.78/120.06 \end{aligned} \quad \text{V}$$

Transformer Primary LL Voltages

$$\begin{aligned} V_{AB} &= 12,458.03/29.97 \\ V_{BC} &= 12,464.22/-90.01 \\ V_{CA} &= 12,464.32/149.95 \end{aligned} \quad \text{V}$$



Neutral to Ground Voltage at Transformer Primary

$$V_{NG} = 0 \quad \text{V}$$

Primary Windings Ideal Voltages

$$VT_{AN} = 7,101.50/-0.95 \quad \text{V}$$

$$VT_{CN} = 6,990.71/120.29$$

Primary Line, Neutral and Ground Currents

$$I_A = 4.2202/-19.26$$

$$I_B = 0$$

$$I_C = 1.8647/60.80 \quad \text{A}$$

$$I_N = 2.2118/-159.62$$

$$I_G = 2.8708/169.27$$

Transformer Secondary Windings Ideal Voltages Transformer Secondary Terminal Voltages

$$V_{tan} = 118.36/-0.95$$

$$V_{tnb} = 118.36/-0.95 \quad \text{A}$$

$$V_{tca} = 233.02/120.59$$

$$V_{an} = 117.44/-1.05$$

$$V_{nb} = 117.30/-1.03$$

$$V_{ab} = 234.74/-1.04 \quad \text{V}$$

$$V_{bc} = 228.11/-120.60$$

$$V_{ca} = 233.02/120.59$$

Transformer Secondary Winding Currents Currents

$$I_{na} = 118.61/-16.77$$

$$I_{bn} = 134.81/-21.45 \quad \text{A}$$

$$I_{ac} = 55.94/60.80$$

Secondary Line, Neutral and Ground

$$I_a = 119.75/-43.91$$

$$I_b = 134.81/158.55$$

$$I_c = 55.94/60.80 \quad \text{A}$$

$$I_n = 10.42/-50.89$$

$$I_g = 8.79/-52.63$$

Secondary Line Voltage Drops

$$v_a = 1.0761/-31.40$$

$$v_b = 1.5204/-175.23$$

$$v_c = 0.4456/103.16 \quad \text{V}$$

$$v_n = 0$$

Single-Phase Load Voltages

$$VL_{an} = 116.52/-0.79$$

$$VL_{nb} = 115.95/-1.10 \quad \text{V}$$

$$VL_{ab} = 232.30/-0.94$$



Single-Phase Load Currents

$$\begin{aligned} IL_{an} &= 25.75/-18.98 \\ IL_{nb} &= 43.18/-32.89 \quad A \\ IL_{ab} &= 43.05/-26.79 \end{aligned}$$

Single-Phase Complex Powers

$$\begin{aligned} S_{an} &= \frac{VL_{an} \cdot (IL_{an})^*}{1000} = 3.0 @ 0.95 PF \\ S_{nb} &= \frac{VL_{nb} \cdot (IL_{nb})^*}{1000} = 5.0 @ 0.85 PF \quad \text{kVA} \\ S_{ab} &= \frac{VL_{ab} \cdot (IL_{ab})^*}{1000} = 10.0 @ 0.90 PF \end{aligned}$$

Motor LL Voltages

$$\begin{aligned} VL_{ab} &= 232.30/-0.94 \\ VL_{bc} &= 226.91/-120.37 \quad V \\ VL_{ca} &= 231.65/120.50 \end{aligned}$$

Motor Line Currents

$$\begin{aligned} IM_a &= 60.06/-66.97 \\ IM_b &= 51.20/172.76 \quad A \\ IM_c &= 55.94/60.80 \end{aligned}$$

Transformer Operating kVAs

$$\begin{aligned} S_A &= \frac{V_{AN} \cdot (I_A)^*}{1000} = 28.67 + j9.92 = 30.34 \text{ kVA} @ 0.95 \text{ PF} \\ S_C &= \frac{V_{CN} \cdot (I_C)^*}{1000} = 6.85 + j11.52 = 13.40 \text{ kVA} @ 0.51 \text{ PF} \end{aligned}$$

INDUCTION MOTOR ANALYSIS

Stotor Input Complex Power

$$\begin{aligned} S_{stator} &= 18.36 + j12.49 \text{ kVA} \\ S_{stator} &= 22.21 \text{ kVA} @ 0.8268 \text{ PF} \end{aligned}$$

Rotor Currents

$$\begin{aligned} I_{rotor a} &= 50.41/-41.89 \\ I_{rotor b} &= 42.67/-157.40 \quad A \\ I_{rotor c} &= 50.09/87.85 \end{aligned}$$

Losses

$$\begin{aligned} Stator_{loss} &= 724.45 \\ Rotor_{loss} &= 623.74 \quad W \\ Total_{loss} &= 1,348.20 \end{aligned}$$

Converted Shaft Power

$$\begin{aligned} P_{converted} &= 17.01 \text{ kW} \\ P_{converted} &= 22.80 \text{ Hp} \quad \text{kW} \end{aligned}$$

NEMA Unbalances

$$\begin{aligned} V_{unbalance} &= 0.1.4663 \% \\ I_{unbalance} &= 8.1399 \end{aligned}$$

