



- ### NUMBERED SHEET NOTES
- 1 SPLIT-WIRED RECEPTACLE WITH TWO DEDICATED BRANCH CIRCUITS, ONE FOR GARBAGE DISPOSAL (CONTROLLED BY ABOVE COUNTER SWITCH) AND THE OTHER FOR DISHWASHER
 - 2 POWER TO OVERHEAD PROJECTOR, COORDINATE WITH AV DRAWINGS.
 - 3 POWER FOR AV EQUIPMENT RACK, COORDINATE WITH AV DRAWINGS.
 - 4 8-WIRE FURNITURE SYSTEM CONSISTING OF 4 HOTS, 2 NEUTRALS AND 2 GROUNDS, HOMERUN 8 -#10 AWG IN 3/4" C OR MULTI-CIRCUIT MC CABLE. CIRCUIT WITH AN ASTERISK "*" IS A CONTROLLED CIRCUIT PER CA T24 130.5(6). CIRCUIT CONTROLLED VIA A CONTACTOR AND TIMELOCK LOCATED IN THE ELECTRICAL ROOM.
 - 5 PROVIDE 120V POWER TO CONDENSATE PUMP.
 - 6 USE BRANCH CIRCUIT EL06C-3 FROM CORE SHELL FOR ADDITIONAL FSD'S.
 - 7 GR000 SERIES WIREMOLD FOR POWER AND DATA DISTRIBUTION FROM COLUMN TO ELECTRIFIED FURNITURE.
 - 8 ROUGH-IN FOR AV ROOM SCHEDULING PANEL. REFER TO THE AV DRAWINGS.
 - 9 ROUGH-IN FOR AV DEVICE, REFER TO AV DRAWINGS.
 - 10 PROVIDE 120V POWER TO MOTORIZED DAMPER, USE 20A CIRCUIT FROM PANEL UL003.
 - 11 COORDINATE MOUNTING OF STARLINE BUS WITH MECHANICAL NOT ABLE DUCT WORK.
 - 12 UPS LIJON BATTERY CABINET REQUIRES 3 FEET CLEARANCE ALL AROUND.
 - 13 CARD READER AND ASSOCIATED ELECTRICAL LOCK SHALL BE DISABLED THROUGH THE SECURITY SYSTEM WHEN THE FIRE ALARM SYSTEM GOES INTO ALARM.

- ### GENERAL SHEET NOTES
- 1 PROVIDE GFCI RECEPTABLES WITHIN 6 FEET OF WATER SOURCE.

Issued For:		
No.	Description	Date
1	75% CD	2018.03.09
2	100% CD (NOT FOR CONSTRUCTION)	2018.06.01
3	100% CD (NOT FOR CONSTRUCTION)	2018.07.12
4	BULLETIN #1	2018.11.08
5	BULLETIN #2	2019.06.12
6	ADDENDUM #27	2019.06.12
7	DB PLAN CHECK REV	2020.01.20
8	ADDENDUM #27 PLAN/CHECK RESPONSE	2020.03.06